

EN50438 for CZ Declaration

We JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO.,LTD.

hereby declares that the inverters model:

GW5048D-ES


GW3648D-ES

Fulfill the default setting of EN50438:2013, except for followed settings:

Parameter	Maximum clearance time s	Maximum trip setting
Over-voltage	0,2	230 V + 15%
Under-voltage	0,2	230 V - 15%
Over-frequency	0,5	52 Hz
Under-frequency	0,5	47,5 Hz


In addition, QU,PU,PF curve details are specified as below, factory setting is on :

1. QU curve



2. PU curve


Where the sun shines there is GoodWe



3. PF curve

Fulfilled default setting of EN50438:2013.

Approver: Jing Xie (谢静)



20170717